

C € 0085



CERT

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CR0399
Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) EG-Gasgeräterichtlinie (2009/142/EG)
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	BLUEHELIX...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K18382016B2 from 27.10.2016 (TRG) type testing: K18392016T1 from 27.10.2016 (TRG) type testing: K18382016B2 rev.03 from 09.03.2017 (TRG)
Test Basis <i>Prüfgrundlagen</i>	2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.01.2013)
File Number <i>Aktenzeichen</i>	16-0382-GEE



70028-04-A-DE

04.04.2017 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Geräte kategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2ELw	20 mbar	PL	
II2E Lw3B/P	20, 30 mbar	PL	
II2E+3P	20/25, 30 mbar	BE, FR	
II2E+3P	20/25, 37 mbar	BE, FR	
II2ELL3B/P	20, 50 mbar	DE	
II2H3B/P	20, 30 mbar	CY, DK, EE, FI, HR, IE, IS, IT, LT, NO, RO, SE, SI, SK, TR	
II2H3B/P	20, 37 mbar	GR, IE, LV	
II2H3B/P	20, 50 mbar	AT, CH, CZ, HR, LU	
II2H3P	20, 37 mbar	ES	
II2HS3B/P	25, 30 mbar	HU	
II2HS3B/P	25, 50 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
BLUEHELIX PRO S 27C	nominal heat output: 5,7...24,5 kW heat input (Hi): 5,8...25,0 (drinking water: ...27,0) kW	
BLUEHELIX PRO S 32C; BLUEHELIX B S 32 K 100	nominal heat output: 6,6...28,9 kW heat input (Hi): 6,7...29,5 (drinking water: ...32,0) kW	
BLUEHELIX TECH S 45 H; BLUEHELIX B S 45	nominal heat output: 7,3...42,1 kW heat input (Hi): 7,5...43,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B33, C13(x), C23, C33(x), C43(x), C53(x), C63(x), C83(x), C93(x): according to installation manual BLUEHELIX...

Additional proved countries of destination, appliance categories and supply pressures:

AL, MK: II2E3B/P (20, 50 mbar)

BG, MT: II2H3B/P (20, 30 mbar)

GB: II2H3P (20, 37 mbar) and II2H3B (20, 30 mbar)

PT: II2H3B/P (20, 37 mbar)

NL: II2EK3B/P (25, 30 mbar)

In Albania and Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.

DVGW