

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CU0181
Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Distributor <i>Vertreiber</i>	Ferrolì S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers: Condensing water heater (3102)
Product Description <i>Produktbezeichnung</i>	Wall-hunging gas fired central heating condensing boiler with integrated gas burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	FORCE W...; FORCE B...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K 2607 2019 T1 from 04.06.2019 (TRG) type testing: K 2607 2019 B2 from 04.06.2019 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Date of Expiry / File No. 11.07.2029 / 19-0346-GEE
Ablaufdatum / AZ

11.07.2019 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
II2E+3P	20/25, 37 mbar	BE, FR	
II2EK3B/P	20/25, 30 mbar	NL	
II2ELL3B/P	20, 50 mbar	DE	
II2ELw3B/P	20, 30 mbar	PL	
II2H3B/P	20, 30 mbar	CY, DK, EE, FI, HR, IE, IS, IT, LT, NO, RO, SE, SI, SK, TR	
II2H3B/P	20, 37 mbar	GR, LV	
II2H3B/P	20, 50 mbar	AT, CH, CY, CZ, HR, LU	
II2H3P	20, 37 mbar	ES, GB	
II2HS3B/P	25, 30 mbar	HU	
II2HS3B/P	25, 50 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B23	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
FORCE W 60	nominal heat output: 14,7...57,0 kW nominal heat input (Hi): 15,0...58,0 kW	
FORCE W 80; FORCE B 80	nominal heat output: 14,7...72,9 kW nominal heat input (Hi): 15,0...74,4 kW	
FORCE W 99	nominal heat output: 18,7...94,7 kW nominal heat input (Hi): 19,0...96,6 kW	
FORCE W 120; FORCE B 120	nominal heat output: 18,7...110,5 kW nominal heat input (Hi): 19,0...113,0 kW	
FORCE W 150; FORCE B 150	nominal heat output: 23,6...140,0 kW nominal heat input (Hi): 24,0...143,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

AL: II2E3B/P (20, 50 mbar)

BG, MT: II2H3B/P (20, 30 mbar)

IE, PT: II2H3B/P (20, 37 mbar)

MK: II2E3B/P (20, 50 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

DVGW